

Practice Customer  
123 Practice Rd  
Dulles, Va 20166  
Attn: John Doe

Date Collected 7/29/2007  
Date Received 7/30/2007  
Date Reported 7/31/2007

Page 1 of 1

**Client Project Name: Demo 8-22-07**

**Project ID: 71234**

Client Sample Number: G21-12

Lab Sample Number: 70027-001

Sample Location: Kitchen 3 Feed Below Top Right Corner of Ceiling

**Test Requested: 1051 Wipe/Tape, Direct Microscopic Exam**

**Results:**

**Laboratory Observation**

Numerous Alternaria spores seen.	3-4 per field* (minimum)
Few Stachybotrys spores seen.	5 per cover slip**
Moderate pollen seen.	1 per 5 fields*

**Comments: Debris Rating 2\*\*\***

Client Sample Number: G21-13

Lab Sample Number: 70027-002

Sample Location: Bedroom, Corner of Wall On Visible Mold Growth

**Test Requested: 1051 Wipe/Tape, Direct Microscopic Exam**

**Results:**

**Laboratory Observation**

Numerous Penicillium/Aspergillus group spores seen.	3-4 per field* (minimum)
Moderate Cheatomium spores seen.	1 per 5 fields*
Occasional Yeast cells seen.	1-5 per cover slip**

**Comments: Debris Rating 1\*\*\***

\* The field of view at 400x magnification

\*\* 20 x 30 mm cover slip placed directly on sample for analysis

\*\*\* See "Footnotes and Additional Report Information" section for explanation of footnotes.