

Certificate of Analysis EMLAP# 102977

43760 Trade Center Place Suite 100 Sterling, Virginia 20166 (877) 648-9150 www.aerobiology.net/

	www.aerobiology.net-
Aerobiology Sample Report 1234 Mold Ave. Spores, Conidiophores 12345 Attn: Fifth Kingdom Project: Legionlla Sample Report Condition of Sample(s) Upon Receipt: Acceptable	Date Collected: 02/16/2015 Date Received: 02/18/2015 Date Analyzed: 03/02/2015 Date Reported: 03/02/2015 Project ID: 15000000 Page 1 of 2
Client Sample #: 1 Sample Location: Laundry Hot Water (Sink) Test: 1015, Water Legionella Analysis, CDC Method Results: Negative for Legionella at 10 days	Lab Sample #: 15000000-001 Liquid Volume: 200 (mL)
Client Sample #: 2 Sample Location: Hot Water Return Boiler Room Test: 1015, Water Legionella Analysis, CDC Method Results: Negative for Legionella at 10 days	Lab Sample #: 15000000-002 Liquid Volume: 200 (mL)
Client Sample #: 3 Sample Location: Cold Water Supply Pump Room Test: 1015, Water Legionella Analysis, CDC Method Results: Negative for Legionella at 10 days	Lab Sample #: 15000000-003 Liquid Volume: 200 (mL)
Client Sample #: 4 Sample Location: Rm 219 Hot Water Test: 1015, Water Legionella Analysis, CDC Method Results: Negative for Legionella at 10 days	Lab Sample #: 15000000-004 Liquid Volume: 200 (mL)
Client Sample #: 5 Sample Location: Rm 219 Cold Water Test: 1015, Water Legionella Analysis, CDC Method Results: Negative for Legionella at 10 days	Lab Sample #: 15000000-005 Liquid Volume: 200 (mL)
Client Sample #: 6 Sample Location: 2nd Floor ICE Machine Test: 1015, Water Legionella Analysis, CDC Method Results: Negative for Legionella at 10 days	Lab Sample #: 15000000-006 Liquid Volume: 200 (mL)
Client Sample #: 7 Sample Location: 2nd Floor South Hot Water Test: 1015, Water Legionella Analysis, CDC Method Results: Negative for Legionella at 10 days	Lab Sample #: 15000000-007 Liquid Volume: 200 (mL)
Client Sample #: 8 Sample Location: 2nd Floor Shower North Hot Water Test: 1015, Water Legionella Analysis, CDC Method Results: Negative for Legionella at 10 days	Lab Sample #: 15000000-008 Liquid Volume: 200 (mL)



Certificate of Analysis EMLAP# 102977

43760 Trade Center Place Suite 100 Sterling, Virginia 20166 (877) 648-9150 www.aerobiology.netA

Aerobiology Sample Report Date Collected: 02/16/2015 1234 Mold Ave. Date Received: 02/18/2015 Spores, Conidiophores 12345 Date Analyzed: 03/02/2015 Attn: Fifth Kingdom Date Reported: 03/02/2015

Project: Legionlla Sample Report Project ID: 15000000 Condition of Sample(s) Upon Receipt: Acceptable

Page 2 of 2

Legionella Facts

1. TESTING METHODOLOGY: Culture remains the recommended method for Legionella monitoring. Standardized culture procedures include ISO 11731: Detection and Enumeration of Legionella and CDC: Procedures for the Recovery of Legionella from the Environment.

Ref: BSR / ASHRE Standard 188P

2. Legionella species recovered from culture method include Legionella pneumophila and Legionella species not pneumophila. All Legionella pneumophila isolates are run against Serogroup 1 reagent. Legionella species not pneumophila isolates are screened in Legionella serogroup / species reagent. (This serogroup reagent includes micdadei, bozemanii, dumoffi, longbeachae, jordanis, gormanii, anisa and feelei)

Action Criteria for Legionella

$lackbox{f ar{f }}}}}}}}}}}}}}}}}$			
Legionella / ml	Cooling Towers and Evaporative Condensers	Suggested Remedial Action: Potable Water	Humidifier/Fogger
Detectable, but <1	1	2	3
1 - 9	2	3	4
10 - 99	3	4	5
100 - 999	4	5	5
≥ 1,000	5	5	5

Remedial Actions:

Level 1:

Review routine maintenance program recommended by the manufacturer of the equipment to ensure that the recommended program is being followed. The presence of barely detectable number of Legionella represents a low level of concern.

Implement action 1. Conduct follow-up analysis after a few weeks for evidence of further Legionella amplification. This level of Legionella represents little concern, but the number of organisms detected indicates that the system is a potential amplifier of Legionella. Level 3:

Implement action 2. Conduct review of premises for the direct and indirect bioaerosols contact with occupants and health risk status of people who may come in contact with bioaerosols. Depending on the results of the review of the premises, action related to cleaning and/or biocide treatment of the equipment may be indicated. This level of Legionella represents a low but increased level of concern. Level 4:

Implement action 3. Cleaning and/or biocide treatment of the equipment is indicated. This level of Legionella represents a moderately high level of concern, since it is approaching levels that may cause outbreaks. It is uncommon for samples to contain number of Legionella that fall in this category.

Level 5:

Immediate cleaning and/or biocide treatment of the equipment is definitely indicated. Conduct post treatment analysis to ensure effectiveness of the corrective action. The level of Legionella represents a high level of concern, since it poses the potential for causing an outbreak. It is very uncommon for samples to contain number of Legionella that fall in this category.

Ref: Legionella: Current Status and Emerging Perspectives: barbaree, Breiman, Dufour: ASM



Suzanne S. Blevins, B.S., SM (ASCP) Laboratory Director

Syan S. Poling