














Aerobiology Sample Report  
43760 Trade Center Place  
Sterling, Virginia 20166  
Attn: John Doe  
Project: **USP 797 Test**  
Condition of Sample(s) Upon Receipt: Acceptable


Date Collected: 06/14/2018  
Date Received: 06/15/2018  
Date Analyzed: 06/20/2018  
Date Reported: 06/21/2018  
Project ID: 18021265  
Page 1 of 4


## AeroMetric 797™ Results Summary Sheet

	Sample Location	Class	Pass	Acpt	O.O.C.	Cause
1	IV Hood 1 ISO Class 5	5				
2	IV Hood 2 ISO Class 5	5				
3	Chemo Room 1 ISO Class 7	7				
4	Chemo Room 2 ISO Class 7	7				
5	Ante Room 1 ISO Class 8	8				
6	Ante Room 2 ISO Class 8	8				
7	Positive Air Control	N/A				
8	Negative Air Control	N/A				
9	IV Hood 1 ISO Class 5	5				
10	IV Hood ISO Class 5	5				
11	Chemo Room 1 ISO Class 7	7				
12	Chemo Room 2 ISO Class 7	7				
13	Anteroom 1 ISO Class 8	8				Maximum count for Class 8 exceeded
14	Anteroom 2 ISO Class 8	8				
15	Positive Surface Control	N/A				
16	Negative Surface Control	N/A				

 No growth of microorganisms. Sample in compliance with USP 797 and CAG-009 guidance documents.

 Growth of microorganisms. Sample in compliance with USP 797 and CAG-009 guidance documents.

 O.O.C. - Out of Compliance. Unacceptable concentrations or presence of actionable microorganisms.  
Sample not in compliance with USP 797 and CAG-009 guidance documents.

 Sample results not applicable to USP 797 and CAG-009 guidance documents.

Aerobiology Sample Report  
43760 Trade Center Place  
Sterling, Virginia 20166  
Attn: John Doe  
Project: **USP 797 Test**  
Condition of Sample(s) Upon Receipt: Acceptable

Date Collected: 06/14/2018  
Date Received: 06/15/2018  
Date Analyzed: 06/20/2018  
Date Reported: 06/21/2018  
Project ID: 18021265  
Page 2 of 4

Client Sample #: 1  
Sample Location: IV Hood 1 ISO Class 5  
Test: 1104, USP 797 Culture, Surface, Bacterial Counts with ID: SOP 2.23  
Results: **No Growth**

Lab Sample #: 18021265-009

Area: **25 (cm<sup>2</sup>)**  
MRL: **1**

Comments: **Pass**

Client Sample #: 1  
Sample Location: IV Hood 1 ISO Class 5  
Test: 1106, USP 797 Culture, Surface, Fungal Counts with ID: SOP 3.9  
Results: **No Growth**

Lab Sample #: 18021265-009

Area: **25 (cm<sup>2</sup>)**  
MRL: **1**

Comments: **Pass**

Client Sample #: 2  
Sample Location: IV Hood ISO Class 5  
Test: 1104, USP 797 Culture, Surface, Bacterial Counts with ID: SOP 2.23  
Results: **No Growth**

Lab Sample #: 18021265-010

Area: **25 (cm<sup>2</sup>)**  
MRL: **1**

Comments: **Pass**

Client Sample #: 2  
Sample Location: IV Hood ISO Class 5  
Test: 1106, USP 797 Culture, Surface, Fungal Counts with ID: SOP 3.9  
Results: **No Growth**

Lab Sample #: 18021265-010

Area: **25 (cm<sup>2</sup>)**  
MRL: **1**

Comments: **Pass**

Client Sample #: 3  
Sample Location: Chemo Room 1 ISO Class 7  
Test: 1104, USP 797 Culture, Surface, Bacterial Counts with ID: SOP 2.23  
Results: **No Growth**

Lab Sample #: 18021265-011

Area: **25 (cm<sup>2</sup>)**  
MRL: **1**

Comments: **Pass**

Client Sample #: 3  
Sample Location: Chemo Room 1 ISO Class 7  
Test: 1106, USP 797 Culture, Surface, Fungal Counts with ID: SOP 3.9  
Results: **No Growth**

Lab Sample #: 18021265-011

Area: **25 (cm<sup>2</sup>)**  
MRL: **1**

Comments: **Pass**

Aerobiology Sample Report  
43760 Trade Center Place  
Sterling, Virginia 20166  
Attn: John Doe  
Project: **USP 797 Test**  
Condition of Sample(s) Upon Receipt: Acceptable

Date Collected: 06/14/2018  
Date Received: 06/15/2018  
Date Analyzed: 06/20/2018  
Date Reported: 06/21/2018  
Project ID: 18021265  
Page 3 of 4

Client Sample #: 4  
Sample Location: Chemo Room 2 ISO Class 7  
Test: 1104, USP 797 Culture, Surface, Bacterial Counts with ID: SOP 2.23  
Results: **No Growth**

Lab Sample #: 18021265-012

Area: **25 (cm<sup>2</sup>)**  
MRL: **1**

Comments: **Pass**

Client Sample #: 4  
Sample Location: Chemo Room 2 ISO Class 7  
Test: 1106, USP 797 Culture, Surface, Fungal Counts with ID: SOP 3.9  
Results: **No Growth**

Lab Sample #: 18021265-012

Area: **25 (cm<sup>2</sup>)**  
MRL: **1**

Comments: **Pass**

Client Sample #: 5  
Sample Location: Anteroom 1 ISO Class 8  
Test: 1104, USP 797 Culture, Surface, Bacterial Counts with ID: SOP 2.23  
Results: **1 CFU/25cm<sup>2</sup>**

Lab Sample #: 18021265-013

Area: **25 (cm<sup>2</sup>)**

Organism(s) Isolated:	Raw Count	CFU/25cm <sup>2</sup>	% Total	MRL
Coag-negative Staphylococcus species	1	1	100	1
	1	1	~100%	

Comments: **Acceptable**

Client Sample #: 5  
Sample Location: Anteroom 1 ISO Class 8  
Test: 1106, USP 797 Culture, Surface, Fungal Counts with ID: SOP 3.9  
Results: **2 CFU/25cm<sup>2</sup>**

Lab Sample #: 18021265-013

Area: **25 (cm<sup>2</sup>)**

Organism(s) Isolated:	Raw Count	CFU/25cm <sup>2</sup>	% Total	MRL
Cladosporium species	2	2	100	1
	2	2	~100%	

Comments: **O.O.C.**

Client Sample #: 6  
Sample Location: Anteroom 2 ISO Class 8  
Test: 1104, USP 797 Culture, Surface, Bacterial Counts with ID: SOP 2.23  
Results: **No Growth**

Lab Sample #: 18021265-014

Area: **25 (cm<sup>2</sup>)**  
MRL: **1**

Comments: **Pass**

Aerobiology Sample Report  
43760 Trade Center Place  
Sterling, Virginia 20166  
Attn: John Doe  
Project: **USP 797 Test**  
Condition of Sample(s) Upon Receipt: Acceptable

Date Collected: 06/14/2018  
Date Received: 06/15/2018  
Date Analyzed: 06/20/2018  
Date Reported: 06/21/2018  
Project ID: 18021265  
Page 4 of 4

Client Sample #: 6  
Sample Location: Anteroom 2 ISO Class 8  
Test: 1106, USP 797 Culture, Surface, Fungal Counts with ID: SOP 3.9  
Results: **No Growth**

Lab Sample #: 18021265-014

Area: **25 (cm<sup>2</sup>)**  
MRL: **1**

Comments: **Pass**

Client Sample #: Control  
Sample Location: Positive Surface Control  
Test: 1154, BACTERIAL SURFACE - USP 797 Positive (+) Control: SOP 2.2  
Results: **Growth**

Lab Sample #: 18021265-015

Client Sample #: Control  
Sample Location: Positive Surface Control  
Test: 1155, FUNGAL SURFACE - USP 797 Positive (+) Control: 3.2  
Results: **Growth**

Lab Sample #: 18021265-015

Client Sample #: Control  
Sample Location: Negative Surface Control  
Test: 1158, BACTERIAL SURFACE - USP 797 Negative (-) Control: 2.2  
Results: **No Growth**

Lab Sample #: 18021265-016

Client Sample #: Control  
Sample Location: Negative Surface Control  
Test: 1159, FUNGAL SURFACE - USP 797 Negative (-) Control: SOP 3.2  
Results: **No Growth**

Lab Sample #: 18021265-016