

Aerobiology Laboratory - VA
43760 Trade Center Place
Sterling, Virginia 20166
Attn: Chris Blevins
Project: **Mycobacterium Testing 1067 1091 1096**
Condition of Sample(s) Upon Receipt: Acceptable

Date Collected: 02/03/2021
Date Received: 02/04/2021
Date Analyzed: 03/17/2021
Date Reported: 03/18/2021
Project ID: 21021360
Page 1 of 3

Client Sample #: 1
Sample Location: Bathroom 1st Floor
Test: 1067, Air, Mycobacterium Culture and Total Bacterial Count
Positive Hole Corrected Result: **10 CFU/m³**

Lab Sample #: 21021360-001
Positive Hole: **219**
Air Volume: **200 (L)**
MRL: **5**

Organism(s) Isolated:	Raw Count	CFU/m ³	% Total	Reservoirs
Mycobacterium chimaera	2	10	100	
	2	10	~100%	

Client Sample #: 1
Sample Location: Bathroom 1st Floor
Test: 1091, Surface / Wipe Mycobacterium Culture and Total Bacterial Count
Results: **10 CFU/in²**

Lab Sample #: 21021360-001
Area: **4 (in²)**

Organism(s) Isolated:	Raw Count	CFU/in ²	% Total	MRL
Mycobacterium gordonae	4	10	100	3
	4	10	~100%	

Client Sample #: 2
Sample Location: Bathroom 2nd Floor
Test: 1067, Air, Mycobacterium Culture and Total Bacterial Count
Positive Hole Corrected Result:

Lab Sample #: 21021360-002
Positive Hole: **219**
Air Volume: **200 (L)**
MRL: **5**

Comments: No Mycobacterium species isolated.

Client Sample #: 2
Sample Location: Bathroom 2nd Floor
Test: 1091, Surface / Wipe Mycobacterium Culture and Total Bacterial Count
Results:

Lab Sample #: 21021360-002
Area: **4 (in²)**
MRL: **3**

Comments: No Mycobacterium species isolated.

Aerobiology Laboratory - VA
43760 Trade Center Place
Sterling, Virginia 20166
Attn: Chris Blevins
Project: **Mycobacterium Testing 1067 1091 1096**
Condition of Sample(s) Upon Receipt: Acceptable

Date Collected: 02/03/2021
Date Received: 02/04/2021
Date Analyzed: 03/17/2021
Date Reported: 03/18/2021
Project ID: 21021360
Page 2 of 3

Client Sample #: 1
Sample Location: Fountain 1st Floor
Test: 1096, Water, Mycobacterium Culture (NTM) and Total Bacterial Count
Results: **<1 CFU/mL**

Lab Sample #: 21021360-003

Liquid Volume: **250 (mL)**

Organism(s) Isolated:	Raw Count	CFU/mL	% Total	MRL
Mycobacterium gordonae	2	<1	100	0.4
	2	<1	~100%	

Client Sample #: 2
Sample Location: Fountain 2nd Floor
Test: 1096, Water, Mycobacterium Culture (NTM) and Total Bacterial Count
Results: **3 CFU/mL**

Lab Sample #: 21021360-004

Liquid Volume: **250 (mL)**

Organism(s) Isolated:	Raw Count	CFU/mL	% Total	MRL
Mycobacterium chimaera	8	3	100	0.4
	8	3	~100%	


Aerobiology Laboratory - VA
43760 Trade Center Place
Sterling, Virginia 20166
Attn: Chris Blevins
Project: **Mycobacterium Testing 1067 1091 1096**
Condition of Sample(s) Upon Receipt: Acceptable

Date Collected: 02/03/2021
Date Received: 02/04/2021
Date Analyzed: 03/17/2021
Date Reported: 03/18/2021
Project ID: 21021360
Page 3 of 3

Signature Page

Aerobiology Laboratory Associates, Inc. shall be responsible for all the information provided in the report, except when information is provided by the customer. Data provided by a customer can affect the validity of results and shall be clearly identified. Results apply to the samples as received. Aerobiology Laboratory Associates, Inc. is not responsible for the sampling activity, such as air and water volume, area and mass unit. The report shall not be reproduced except in full without the approval of the laboratory to ensure that parts of a report are not taken out of context. Data interpretation of this report will be the client responsibility based on their sampling.

1. Aerobiology Laboratory Associates Incorporated maintains accreditation with the American Industrial Hygiene Association Laboratory Accreditation Programs (AIHA LAP), LLC - Environmental Microbiology Laboratory Accreditation Program (EMLAP) in compliance with ISO 17025:2017.
2. Aerobiology Laboratory Associates Incorporated maintains accreditation and certification with local and state agencies where our laboratories are located.
3. Aerobiology Laboratory Associates Incorporated is certified by the state of Virginia as a Small, Woman and Minority (SWaM) business.
4. Aerobiology's New Jersey location has been approved by the New York Department of Health (ELAP) to analyze Legionella samples for POTABLE WATER and NON-POTABLE WATER.
5. Aerobiology Laboratory Associates Incorporated is a for-profit, privately held company, incorporated in the state of Virginia in 1997.
6. The results in this report are related to this project and these samples only.



Suzanne S. Blevins, B.S., SM (ASCP)
Laboratory Director